

SK DECLARATION OF PARAMETERS

Nr. 04/2013

1. Product type: **Electrical cables**
2. Product name: **J-H(St)H with variant SHKfH-R**
3. Slovak norm related to the product: **STN 34 7661: 2012 Products for distribution of electricity, control and communication for purposes of fire safety of buildings. Cables and conductors.**
4. Intended use:
- for the purpose of limiting the spread of fire, production of heat, smoke, burning particles, drops and corrosive substances during fire on cable products (reaction to fire and additional classifications)
5. Company name, contact address of the manufacturer and company ID: **ELKOND HHK a.s., Oravická 1228, 028 01 TRSTENÁ, SLOVAK REPUBLIC, Company ID nr. 36382841**
6. System for assessment of parameters: **System I+** according to Ministry of Transport, Construction and Regional Development of the Slovak Republic Decree Nr. 162/2013, which establishes a list of groups of construction products and systems for assessment of parameters: **Item 3601**
7. SK certificate: SK CERTIFICATE OF CONFORMITY SK04-ZVS-1710 issued 25.9.2012 by the Technical and testing institute of constructions
8. Declared parameters

Essential properties	Parameter	Test protocols, norms, etc.	Laboratory
Reaction to fire	B _{2ca}	903568-01/01	1
Additional classification	-s1, d0 a1	903568-01/01 203115-02/01	1

Laboratory	Name and address of the test laboratory
1	Elektrotechnický zkušební ústav, s.p. Praha, Pod Lisem 129, 171 02 Praha 8 – Troja, ČR

9. Parameters of the product identified in points nr. 1 and 2 are in conformity with parameters declared in the point 8.
10. This SK Declaration of parameters is issued under the sole responsibility of the manufacturer identified in the point nr. 5.

Zdenko Krajč, General Director and Chairman of the Board

.....
(Signature)

Ing. Eva Vaterková, Member of the Board

.....
(Signature)

In Trstená 1.7.2013